

VER 1.0

Technical Manual

DS-CL28-SA / DS-CL42-SA



Table of Contents

C

[Click to return to table of contents](#)

1. Before Getting Started

3

2. Windows of Position Table.....

4

2.1 Loading Position Table Data.....

4

2.2 Main Window of Position Table.....

5

2.3 Position Table Editor.....

7

3. Position Table Item.....

9

3.1 Explanation of Position Table Item.....

9

3.2 Type of Command.....

12

4. Execution of Position Table.....

13

4.1 How to Start Position Table.....

13

4.2 Example for General Operation.....

13

4.3 Operation Modes.....

14

4.3.1 Normal.....

14

4.3.2 Single Step.....

15

4.4 Teaching Function.....

16

4.4.1 Teaching by User Program.....

17

4.5 Input Condition Jump.....

18

4.5.1 Automatic Jump.....

18

4.5.2 Jump by External Signal.....

19

4.6 Loop Condition Jump.....

20

4.6.1 Specifying Loop.....

20

4.6.2 Loop Counter Clear.....

21



1. Before Getting Started

Presented [**DS-CL28/42-SA Technical Manual “ Position Table”**] explains position table functions of DS-CL28/42-SA. Here are [**Technical Manual_ Text**], [**Technical Manual _Communication Function**] in this manual. Please utilize our product afterward understanding about proper usage method with reading these contents carefully.

The word as 'Position Table' can be presented as PT (Position Table) from the following text. In particular, Please don't forget to memorize whole matters that requires attention about safety in [**Technical Manual_ Text**] and should try to understand properly. Besides please be safe to do not use the products improperly in any case. At worst, serious damage can be occurred as like death. We provide this instruction manual and other instruction manual as well. Please keep these manuals in appropriate place whenever you need to find and read comfortably.


This manual is used for DS-CL28/42-SA

2. Windows of Position Table

2.1 Loading Position Table Data



When click the 'Pos Table' button on main menu of User Program(GUI), then the system displays the following message box and loads data saved in RAM area of drive.



Functions of Position Table allows to process motions in the orders that were predefined by user. In the case of this DS-CL28/42-SA, up to 256 steps can be saved.

Major functions for saving items are shown as following:


- (1) Editing function of Motion step (Input/Edit/Delete/Copy)
- (2) Start and Stop function of Motion order at User Program(GUI)
- (3) Start and Stop Motion function by signal input from outside drive
- (4) Teaching function
- (5) Functions to save Motion steps as file and to load them from file
- (6) View function of current Position Table order under execution status

When electric power is supplied to drive, the Position Table data saved in ROM area of drive is copied to RAM area and once click the 'Post Table' button, then the system loads the data saved in RAM area of drive.


2.2 Main Window of Position Table



The following window describes windows and buttons which execute the position table function.



Button	Description
Normal/Single Step	The user can select modes to execute the position table. Normal : All position commands are in order executed according to conditions saved in the position table. Single Step : Only single position command is executed.
Run/Stop/Next	To run/stop items at the defined position table
Teaching	Teaching is executed by either using external input signal or user program. By clicking this button, the user can easily use teaching function at the user program window. For more information, refer to 'Teaching Function'.
Refresh	To display the position value measured by the teaching function. For more information, refer to 'Teaching Function'.
Save to ROM	To save current position table data in ROM drive.
Load from ROM	To open position table data saved in ROM drive
Save to file	To save current position table data to an external file (It is saved to a folder defined by the user with a file name defined by the user. The extension are "txt" and "xlsx".)


Button	Description
Load File	<div><p>To read position table data saved in external file</p></div>

- * Up to 256 position table commands can be input and saved for DS-CL28/42-SA.
- * By using each position table command, the user can edit the file such as edit, copy, paste, and delete.

2.3 Position Table Editor



When click right mouse button on a selected Position Table data line, then the following popup menu is activated.



- (1) Edit Item: You can edit data on the following dialog box shown as below.
- (2) Clear Item: All the items of selected PT are cleared.
 After executing this function all the items are shown as blank.
- (3) Clear All Items: While above function "Clear Item" clears data for one selected order, this function clears data for all the orders of 256 Position Table.
- (4) Cut Item: Used to cut selected item data of PT in order to paste on other position.
- (5) Copy Item: Used to copy selected item data of PT in order to paste on other position.
- (6) Paste Item: Paste the copied data to clipboard by "Cut" or "Copy" to other selected position.
- (7) Run Item: Execute motion order from the selected No. of Position Table.

Double click on selected line of Position Table data or click the “Edit Item” from popup menu button shown above figure, then the dialog box shown right is activated.

Once complete editing of each item, and then you move and select other items to edit by using right/left arrow key.

After complete editing of all data completely, click ‘Save’ button to save data to RAM.

In order to save data to ROM area, click ‘Save to ROM’ button on main screen of Position Table.

The image displays three sequential screenshots of the 'PT Item Editor' dialog box, each showing a different tab: 'Motion', 'Jump', and 'PT Output'.


- Motion Tab:** Features a 'Command' dropdown set to 'ABS - Normal Motion'. Below are input fields for 'Position' (32000 [pulse]), 'Low Speed' (1 [pps]), 'High Speed' (250000 [pps]), 'Accel Time' (100 [msec]), and 'Decel Time' (100 [msec]). There is a checked 'Check Inposition' checkbox and a 'Waiting time after command' field set to 0 [msec].
- Jump Tab:** Also shows 'Command' as 'ABS - Normal Motion'. It includes a 'JP Table No.' field (1) with a checked 'Next No.' checkbox. Below are checkboxes for 'JPT 0', 'JPT 1', and 'JPT 2'. A 'Counting Loop' section contains a 'Loop Count' field and a 'JP Table No. at the end of loop' field. A 'Clear Loop Count' section has a 'JP Table No.' field.
- PT Output Tab:** Shows 'Command' as 'ABS - Normal Motion'. It has a 'PT Output Set' checkbox and three radio buttons for 'Start Sign', 'End Sign', and 'Pass Sign'. An 'Output' section has checkboxes for 'PT 0', 'PT 1', and 'PT 2'. A 'Pass Sign' section includes 'Trigger Position' (0 [pulse]) and 'Trigger Time' (0 [msec]) fields.

Each dialog box has 'Write' and 'Cancel' buttons at the bottom right.

3. Position Table Item


3.1 Explanation of Position Table Item



Designated Item	Description	Unit	Lower limit *1	Upper limit *1
Command	Specifies type of motion. For more details, refer to 「3.2 Command」.	—	0	9
Position	Specifies position/movement scale by number of pulse.	pulse	-2,147,483,648	+2,147,483,647
Low Speed	Specifies low speed by number of pulse in accordance with type of motion. For more details, refer to 「3.2 Command」.	pps	1	35,000
High Speed	Specifies high speed by number of pulse in accordance with type of motion. For more details, refer to 「3.2 Command」.	pps	1	800,000*1 500,000*2
ACC time	Specified acceleration time by msec when starting motion.	ms	1	9,999
DEC time	Specified acceleration time by msec when stopping motion.	ms	1	9,999
				
Wait time	Specifies waiting time by msec for starting motion of next PT when specifying PT No. for jump/skip. If JP Table No is specified as blank, this is ignored.	ms	0	60,000

* 1 : DS-CL28-SA

* 2 : DS-CL42-SA


Notes

Even if Wait Time is specified as 0[ms], the system waits for the completion signal of position setting (INP signal) or motor stop signal before starting next Position Table

JP Table No.				
	When this item specified, the system jumps to JP Table No and execute it after completing action of current position. If Position No is specified as 10XXX, system jumps to Position No XXX as soon as 'JPT Start' begins, one of the input digital signal from controller to outside, becomes ON. For program exit, specify as blank. For more details, refer to 「4.4 Input Condition – Jump」.	—	0	255
			10,000	10,255
JPT 0	If any of these items is checked and there are corresponding input signals of JPT input0, JPT input1 or JPT input2, system jumps to JPT 0, JPT 1 or JPT 2 accordingly regardless of specified 'Jump Table No.'	—	0	255
			10,000	10,255
JPT 1			0	255
			10,000	10,255
JPT 2	For more details, refer to 「4.4 Input Condition Jump」.		0	255
			10,000	10,255

		<table><tr><th>Input signal</th><th>Corresponding Input Jump Position</th></tr><tr><td>JPT input0</td><td>Input Jump Position No 0</td></tr><tr><td>JPT input0</td><td>Input Jump Position No 1</td></tr><tr><td>JPT input0</td><td>Input Jump Position No 2</td></tr></table>			Input signal	Corresponding Input Jump Position	JPT input0	Input Jump Position No 0	JPT input0	Input Jump Position No 1	JPT input0	Input Jump Position No 2
Input signal	Corresponding Input Jump Position											
JPT input0	Input Jump Position No 0											
JPT input0	Input Jump Position No 1											
JPT input0	Input Jump Position No 2											
Loop Count	If these item are specified, system repeats action of the position under specified times (Loop Count) and after then jumps to corresponding position to Loop Jump Table No regardless of specified 'Jump Table No'.	—	0	100								
Loop Jump Table No.	For more details, refer to 「4.5.1 Loop Setting」 .		0	255								
			10,000	10,255								
PT set	Note) ALL28 V2 does not support this functions.		-	-								
Loop Counter Clear	If this item is checked, Loop Count of specified no of PT is to be cleared. For more details, refer to 「4.5.1 Loop Setting」 .	—	0	255								
Check Inpos	If this item is checked, stop condition is recognized as Inposition finishes.	—	0	1								
Trigger Pos	Note) ALL28 V2 does not support this functions	—	—	—								
Trigger Time	Note) ALL28 V2 does not support this functions.	—	—	—								

*1 : The unit of [pps] in this item is referenced to 16,000/revolution encoder.

3.2 Type of Command



Item “Command” specifies type of action pattern to be executed for each position and the followings in the table are list of commands.

Command Name	Specified Value	Remark
Abs Move low speed.	0	The value in the item “Position” is value for absolute position. ‘Teaching’function can be used. ‘Continuous Action’function can be used.
Abs Move high speed	1	
Abs Move high speed with deceleration.	2	
Abs Move with acceleration and deceleration.	3	
Inc Move low speed.	4	The value in the item “Position” is value for relative position. ‘Teaching’function is not supported. ‘Continuous Action’is not supported.
Inc Move high speed	5	
Inc Move high speed with deceleration.	6	
Inc Move with acceleration and deceleration.	7	
Move to Origin	8	Execute the command to move to origin based on the specified current parameters specified.
Clear Position	9	Reset ‘command position’ value and ‘actual position’ value based on current position and clears the values as 0.

The following table shows speed patterns for each action of command.

Command Name	Specified Value	Speed Pattern
Abs Move low speed.	0	
Inc Move low speed.	4	
Abs Move high speed	1	
Inc Move high speed	5	
Abs Move high speed with deceleration.	2	
Inc Move high speed with deceleration.	6	
Abs Move with acceleration and deceleration.	3	
Inc Move with acceleration and deceleration.	7	

4. Execution of Position Table



When installing User Program(GUI), the following files are saved in the folder named as “\DINGS\Ezi-MOTION Plus-RnE\PT Samples_PlusR\ DS-CL28/42”as sample files to test Position Table.

1) General Motioning.txt, 2) Loop Motioning.txt, 3) Loop counter clear.txt, 4) Clear Position.txt

4.1 How to Start Position Table



Position Table operation is executed by input signal or communication command. The followings are example of Position Table operation by input signal to be explained step by step.

In the case of Position Table operation by communication command, the system is executed by sending the communication commands corresponding to the control input signal.

1. Specify Position Table No (0~255) operated by PT A0~PT A7.
2. If the motor is Servo OFF, click Servo ON.
3. Signal ON of PT Start input to start operation.


4.2 Example for General Operation



Specify PT No through input data for PT A0 ~ PTA7 and then input 'PT Start' signal to start speed control operation.

[Specifying Position Table]

PT No	Command type	Position	Low Speed	High Speed	Accel time	Decel. time	Wait time	Continuous Action	JP Table No.
0	3	10000	1	2500	50	300	0	1	1
1	3	1000	1	500	-	-	0	1	2
2	3	5000	1	1500	50	300	300	0	3
3	3	-2500	1	1000	300	300	0	0	-




* Refer to the sample file for testing Position Table, 'PT sample (General Motioning).fpt'.

4.3 Operation Modes



Position Table commands can be executed by two modes as follows.

4.3.1 Normal




Select 'Normal' at the main window of position table, and all commands will be executed in order by conditions already loaded in PT data.

- (1) While Normal mode is selected, the user sets PT number to 0 and click 'Run' and then PT 0 is executed.
- (2) PT 1 is executed by PT data jump conditions.
- (3) PT 2 is executed by PT data jump conditions.
- (4) As mentioned above, next PT number is automatically executed by position data jump conditions.
- (5) Click 'Stop' to stop operating.

4.3.2 Single Step



Select 'Single Step' at the main window of position table, and only corresponding PT command will be executed and next PT commands will be on stand-by. This mode can be easily used when the user executes testing for each position command. And it is available for User Program(GUI) only.



- (1) While Single Step Mode is selected, the user sets PT number to 0 and click 'Run' and then PT 0 is executed.
- (2) After execution is stopped, 'Run' icon is changed into 'Next' and next command is on stand-by.
- (3) Click 'Next' button, and PT 1 will be executed.
- (4) When pressing each 'Next' button, one PT command is executed.
- (5) Click 'Stop' to stop operation. After operation is stopped, the user can set new PT number and click 'Run' button to start the program again.

4.4 Teaching Function



Teaching signal functionalizes that the position value[pulse] being working can be automatically inputted into a 'position' value of a specific position table.


The following table shows type of commands and whether teaching function can be used or not.

Command Name	Value	To be used or not
Abs Move low speed.	0	'Teaching' can be used.
Abs Move high speed	1	
Abs Move high speed with deceleration.	2	
Abs Move with acceleration and deceleration.	3	
Inc Move low speed.	4	'Teaching' cannot be used.
Inc Move high speed	5	
Inc Move high speed with deceleration.	6	
Inc Move with acceleration and deceleration.	7	
Move to Origin	8	
Clear Position	9	

4.4.1 Teaching by User Program



When click 'Teaching' button on Position Table screen, the following dialog box is activated.



- ① Select Position Table No, the figure shows that no 6 of PT is selected among 256 Position Tables.
- ② Specify position of motor where to teach and move it.
- ③ Turn ON or OFF of Servo during teaching.
- ④ Displays current position information and the value displayed in "Actual Pos(ition)" is to be teaching value.
- ⑤ When clicking this "Teaching" button, current value displayed in "Actual Pos" will be saved in the item "Position" of the current PT (No 6 above case). The values are to be saved on RAM and click 'Save to ROM' button in order to save on ROM.
- ⑥ In order to move to the next position, select PT no by using arrow keys.

4.5 Input Condition Jump



Among the items to be specified, “JP Table No.”, “JPT 0”, “JPT 1”and “JPT 2” are used to specify next PT no. to be executed. Specified next PT no. to be executed, there are two different methods depending on the control signal as followings:

4.5.1 Automatic Jump




This is the method to specify next action pattern (PT no.) by input condition. System jumps to next PT no. to be executed automatically according to procedure.

For example as shown in the following figure, when PT no. 14 is executing, 1) if there is no input signal, next action pattern is to be executed by PT no. 15 as shown in figure 1).

However, if any of input signal is ON such as JPT Input0, JPT Input1 or JPT Input2 during the operation of PT no. 14, then system jumps to JPT 0, JPT 1 or JPT2 accordingly and execute it that is specified in the Position Table data as shown in the figure 2) ~ 4).

Data for PT no. 14

PT No (CMD)	Position Table No to Jump (JP Table No.)	Input Jump Position No 0 (JPT 0)	Input Jump Position No 1 (JPT 1)	Input Jump Position No 2 (JPT 2)
14	15	115	116	225



* Refer to the sample file for testing Position Table, ‘PT sample (Loop Motioning).fpt’.

4.5.2 Jump by External Signal



This is the method to specify next action pattern (PT no.) by input condition. However, system does not jump to next PT no. to be executed automatically according to procedure, but executed by external signal (“JPT Start”).

Difference from the function in ‘**section 4.5.1**’executed by input signal JPT Input0~Input2





(1) Jump Position No to jump need to have the format of 10XXX and

(2) ‘JPT Start’ needs to be [ON] in order to execute the next action.

If specified “Wait Time” of PT data is more than 0, then the next action is to be executed after the specified time from the external signal.

Data for PT no. 14

PT No (CMD)	Wait Time (Wait Time)	Position Table No to Jump (JP Table No.)	Input Jump Position No 0 (JPT 0)	Input Jump Position No 1 (JPT 1)	Input Jump Position No 2 (JPT 2)
14	0	10015	10115	10116	10225



* If more than 2 signals become [ON] of 3 ‘Input Jump Position No0 ~ Input Jump Position No2’, the lower number (JPT0 > JPT1 > JPT2) has the high-priority and will be executed.

4.6 Loop Condition Jump

4.6.1 Specifying Loop




If [Loop Count] and [Loop Jump Table No] are specified, system repeats the action of position specified times (Loop Count) and then jumps to corresponding position to [Loop Jump Table No.] regardless of specified [Jump Position No], that is, [Jump Position No] is ignored.

There are rules in specifying loop as following:

- (1) If '0' is specified for [Loop Count], loop function is cancelled.
- (2) If system needs to jump before repeating the specified times, it jumps to JP Table No.
- (3) If 'blank' is specified for [Loop Jump Table No], system exits in execution.
- (4) If [Loop Jump Table No] is specified in the form of 10XXX, next action is executed by the external signal "JPT Start".

Following Table is one of example for specifying loop.

PT No (CMD)	Movement Scale (Position)	Position Table No to jump (JP Table No.)	No of Loop (Loop Count)	Position Table No to jump after completing loop (Loop Jump Table No)	Loop Counter Clear (Loop Counter Clear)
0	8000	1	0	0	-
1	4000	0	2	2	-
2	0	0	3	-	1



* Refer to the sample file for testing Position Table, 'PT sample (Loop Motioning).fpt

4.6.2 Loop Counter Clear




“Loop Counter” is internal counter in drive to compare no. of repeat with the no. specified in the item “Loop Count” of PT data.

This function clears “Loop Counter” to 0 (zero) of the specified PT data after completion of looping. If [Loop Count Clear] is specified as blank, this function is cancelled.

Following table shows an example of specifying Loop Counter Clear

PT No (CMD)	Movement Scale (Position)	Position Table No to jump (JP Table No.)	No of Loop (Loop Count)	Position Table No to jump after completing loop (Loop Jump Table No)	Loop Counter Clear (Loop Counter Clear)
0	8000	1	0	0	-
1	4000	0	2	2	-
2	0	0	0	0	1

- (1) Specify “Loop Counter Clear” of PT No 2 as PT No ‘1’.
- (2) Start operation from PT No 0. When starts operation, system reset all “Loop Count” values as 0 (zero).
- (3) After repeats the loop block PT No 0 ~ PT No 1 two times, the “Loop Counter” becomes 2 (two) same as specified “Loop Count” so system completes looping and jumps to PT No 2.
- (4) After executing PT No 2, system jumps to PT No 0. Before jumping to PT No 0, system clears “Loop Counter”- the internal counter as 0 (zero). (5) Then paragraph (3) and (4) are repeated infinitely.
- (6) If the “Loop Counter Clear” of PT No 2 was not specified, “Loop Counter” increased continuously and so jumping to PT No 2 occurs only once at the first time and then repeats the loop block PT No 0 ~ PT No 1 infinitely because the internal counter “Loop Counter” value will never meet the specified “Loop Count” value.



* Refer to the sample file for testing Position Table, 'PT sample (Loop counter clear).fpt.

International Customer

Person in Charge : **Daniel Jang**

daniel@dingsmotion.com

No.9, Lijiang Road New District,
Changzhou Jiangsu, China

+86-519-85177826, 85177827

North America Customer

Person in Charge : **Nicolas Ha**

nha@dingsmotionusa.com

335 COCHRANE CIRCLE
MORGAN HILL, CA 95037

+1-408-612-4970

China Customer

Person in Charge : **Sweet Shi**

slq@dingsmotion.com

No.9, Lijiang Road New District,
Changzhou Jiangsu, China

+86-519-85177826, 85177827

DINGS

Precision Motion Specialist



+86-0519-8517 7825



+86-0519-8517 7807



No.9, Lijiang Road, New District, Changzhou
Jiangsu, China [Zip Code 213022]



www.dingsmotion.com